



Architecture assessment for safety critical plant operation using reachability analysis of timed automata

David Gouyon, Jean-François Pétin, Thomas Cochard, Catherine Devic

► To cite this version:

David Gouyon, Jean-François Pétin, Thomas Cochard, Catherine Devic. Architecture assessment for safety critical plant operation using reachability analysis of timed automata. Reliability Engineering and System Safety, 2020, 199, pp.106923. 10.1016/j.ress.2020.106923 . hal-02514845

HAL Id: hal-02514845

<https://hal.science/hal-02514845>

Submitted on 23 Mar 2020

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

Architecture assessment for safety critical plant operation using reachability analysis of timed automata

David Gouyon^{a,*}, Jean-François Pétin^a, Thomas Cochard^a, Catherine Devic^b

^a*Université de Lorraine, CNRS, CRAN, F-54000 Nancy, France*

^b*EDF (Electricité de France), R&D, F-78400 Chatou, France*

Abstract

This article deals with the validation of critical industrial process architectures from the point of view of safety and operation. During the engineering phases, the objective is to complement conventional safety studies with an approach that focuses on plant operation. In this context, one of the major challenges is to provide a guarantee that the designed architecture will be able to react safely to critical situations and events.

To face the complexity resulting from the large number of functionalities and devices of the installations under consideration, the proposed approach is based on dynamic models of architectures, using the formalism of timed automata and reachability analysis to verify that, given a particular configuration of an architecture, the process can be safely operated to achieve a given objective. The result is a formal tool that allows engineers and plant operators to evaluate architecture safety with different types of dysfunctional scenarios based on their operational safety expertise.

The article presents the formal modelling framework, which emphasizes structured modelling using patterns to promote reuse and instantiation over several candidate architectures. The contribution is illustrated and discussed using an experimental laboratory platform.

Keywords: Plant operation, safety assessment, critical process architecture, reachability analysis, timed automata, modelling patterns

1. Introduction

Industrial processes involving field devices such as transmitters and actuators that are controlled, monitored and operated manually by human operators, numerical systems and controls, and control and data acquisition systems (SCADA) are complex systems. Their architectures make extensive use of func-

*Corresponding author

Email address: david.gouyon@univ-lorraine.fr (David Gouyon)

tional and physical redundancies, as well as exclusions, to ensure safety.

In addition to conventional safety studies (qualitative assessment of accident scenarios, RAMS forecasts, etc.), the operational availability and safety of plant operating scenarios must be assessed. Given the large number of possible scenarios, due to the redundancies and complexity of industrial installations, operational validation is rather carried out *a posteriori* on the basis of architecture proposals. This is dealt with during the engineering phases but must include feedback from human operators who must deal, day after day, with the various situations of danger and operation of the entire system. Indeed, some operating scenarios using redundancies may be imagined during the engineering phase but considered inappropriate or even prohibited by operators' practices [1].

The work presented in this document was supported by the Connexion project (French Excellence in Nuclear Control Systems). The document proposes a formal approach based on a dynamic process model to help designers and operators perform an automatic analysis of the reachability of situations. The objective is to prove that an architecture provides at least one solution to operate the system safely in order to achieve a targeted situation from a current situation. The added value of operators lies in the provision of significant initial and targeted situations and in the analysis of safety based on practical considerations.

Finally, several candidate architectures can be evaluated during the engineering phase and, therefore, several safety models must be built. A practical consideration of the work for reducing resource consumption, in terms of manpower and time, is to promote modularity and reuse of models.

This article is organized into six sections. The following section presents the industrial context and the problem. The section 3 provides a brief overview of the related works. The section 4 provides an overview of the proposed approach to architecture evaluation, including the selected formalism of timed automata and the generation of action sequences. The modular pattern-based modeling framework is then detailed in the section 5 devoted to architecture and sequencer modeling. The proposed approach is illustrated and discussed using a case study in the section 6.

2. Industrial context and problem

This article focuses on large industrial processes involving thousands of field devices (transmitters and actuators) to perform a variety of functions. These devices can be manually operated and monitored by human operators, automated reflex control systems and SCADA systems. The control of the plant consists in defining an ordered sequence of control and monitoring tasks to be applied to the devices (opening or closing of valves, consignment of devices, etc.), in order to manage the evolutions of the plant. In other words, from a current situation

50 including the values of the process physical variables (such as temperature or
pressure...), the state of the devices (such as idle or locked...), the state of the
functions (filling of a tank in progress, pressurization of a fluid circuit...) and
the process (reactor shutdown, rated production...), the objective is to find an
appropriate and safe sequence of actions to achieve a predicted process situa-
55 tion. Such a sequence must satisfy logical (e.g.: priority rule), temporal (e.g.:
minimum time to operate a device) and physical (e.g.: threshold required for
physical values) constraints.

In the case of critical process systems, plant operation is generally under the
control and validation of human operators who refer to predefined and quali-
60 fied procedures. This activity is complex because architectures massively use
functional and physical redundancies, as well as exclusions to ensure security.
This complexity makes it difficult to assess, from a safety perspective, all possi-
ble operational scenarios [2], predict and control possible interference between
devices or functions, and anticipate blockings.

65 During the engineering phase, the safety assessment aims to demonstrate
that the plant has sufficient redundancies to deal with any critical situation.
More precisely, the process architecture is designed in such a way that there is
at least a safe sequence of actions that an operator can activate, from a current
process situation, to achieve the expected state and status of the process. This
70 validation activity can be performed manually by experienced operators but its
level of confidence is questionable because it seems quite impossible for opera-
tors to consider all potentially possible scenarios [3, 4, 5].

The industrial problem is then to validate the architectures with regard
75 to safety and operational requirements using formal model-based approaches.
This activity is carried out from the early stages of architectural engineering
and places the human operator "in the loop" to confirm the operational avail-
ability and safety of the designed architectures. It requires helping engineers
and operators to perform an automatic analysis of the reachability of situations.
80 In other words, the objective is to generate an acceptable sequence of actions to
demonstrate that the process can be safely operated to reach a planned situa-
tion. If the situation is not reachable, it can lead to a redesign of the functional
and/or organic architecture of the system.

3. Related works

85 According to the industrial requirements of section 2, the qualitative eval-
uation of architectures is assumed to be based on demonstrating the existence
of a safe sequence of actions to reach a target state from a source state. Ex-
isting approaches can be classified into two categories: static models describing
the plant structure (Boolean models, graph-based models, etc.) and dynamic
90 models whose system behaviour is characterized by a state space.

Typically, static analysis of architecture safety takes into account the re-
lationships between a combination of faulty devices and the occurrence of a
dangerous event. The most frequently used Boolean models are event or error

95 trees. They are suitable for modelling non-repairable systems (such as safety
or protection systems) and have a static set of faulty event sequences. Graph-
based approaches can be considered by assuming that the generation of action
sequences can be given, in a first approximation, by a path search in a graph
representing the stabilized situations of the process to be operated. This type of
sequence synthesis has been first applied in the chemical industry by [6] which
100 proposed a method for automatically generating routes from the initial state to
the expected state of a plant, taking into account safety rules, but without tak-
ing into account structural elements or physical values. In practice, the problem
is more complex because the dynamics of the plants (operating mode, value of
physical variables, etc.) must be taken into account:

- 105 • redundancies provide several operating scenarios, but their operational
availability depends on the state of the process (for example, some physical
values must have reached a given threshold in order to use some devices),
- the complexity of the architectures makes it difficult to take into account
all possible scenarios [7]; the analysis can focus on some of them and
110 requires initializing the analysis models with the accurate parameters.

The consideration of dynamic characteristics leads to a shift to state space
models that can be used, depending on their deterministic or stochastic charac-
teristics, to analyze sequences with two types of problem solving: determination
and probability evaluation of event sequences [8]. Since the problem focuses on
115 the deterministic generation of a sequence of actions, the probabilistic evaluation
of architectures is outside the scope of this article and the required models will
not address probabilities. In addition, this article assumes that a discrete and
simplified representation of the evolution of physical values must be sufficient to
solve this problem. Consequently, it is proposed that dynamic representations
120 of the architecture be based on discrete event system models [9].

In the context of deterministic systems, the most commonly used state mod-
els are finite state automata (and language theory) and Petri nets [10]. Hybrid
automata [11] also seem to be an interesting way to represent the structure and
125 behaviour of the physical process. In the field of plant operation engineering,
the graphical representation of operation can be done with different languages,
such as OPNet (Operation Procedure NETwork) [12], Petri nets [13], UML
based approaches [14], Grafchart models [15], the procedure-oriented graphical
notation ProcGraph for the specification of the process control software [16] or
130 the FRDL (Formal Recipe Description Language) [17]. On the basis of these
Discrete Event Systems representations, the problem of sequence determination
can be considered as a research and trajectory analysis in a state space charac-
terizing the evolutions of a set of dynamic models. Several formal approaches
can be considered, such as verification of safety properties, synthesis and anal-
135 ysis of reachability.

Formal verification is the provision of mathematical evidence that the operation of a given architecture meets certain safety and performance properties. The main approach is based on the verification of the model [18] which is an automatic technique of state spatial exploration in relation to properties expressed in a formal logic. It applies to prove the safety of the installation's operating procedures, which are *a priori* known [19, 20, 2], which is not the case for our problem.

The automatic control synthesis techniques [21, 22] define all possible paths in a controller model that meet a set of behavioral specifications. These techniques have been used to generate action sequences for plant operation using Petri nets [23] and state machines [24]. However, they require the modelling of a specification that presents certain choices in terms of plant operating behaviour. This is obviously not the best way to prove the existence of a safe sequence, whatever the specification.

Finally, reachability analysis clearly appears to be the appropriate means of solving the problem of qualitative evaluation of architectures and proving the existence of a legal and safe sequence from one state to another. Among the different reachability analysis techniques, model-checking can be used by considering the properties to be proven [25] as a reachability property. In case of existence, the model-checker returns a single sequence, represented by a trace, among all the possibilities. This technique has already proven its effectiveness, using the Timed Automata [26], in the field of operation [27, 28]. For hybrid automata, the reachability problem can be undecidable, which makes them unusable for an approach to analyse reachability. Although the extension to industrial installations is still an open issue, the existing literature shows the advantage of using reachability analysis on Timed Automata models to generate secure process operations.

4. An architecture assessment approach based on reachability analysis

4.1. Objectives and hypotheses

This work focuses on the early validation of the architecture of critical complex systems in the context of plant operations. The objective is to provide designers and human operators with formal models to prove that the plant can be operated safely, particularly in critical situations, and that the architecture design provides capabilities to achieve safe states. The role of the operators is to identify critical plant operations and to introduce into the models the precise parameters that characterize the situation being analyzed.

According to related work, timed automata (TA) and model-checking reachability analysis appear to be an effective means of demonstrating the existence of at least one sequence of actions satisfying the safety and time constraints for reaching an expected process state from the current state. If the existence of at least one sequence is demonstrated, the process architecture will be considered as valid for the analyzed situation.

180 Two main hypotheses are retained to enrich the TA related works in the case of large industrial systems: the size and complexity of the models, and the practicability of the approach in an engineering process where several candidate architectures have to be evaluated.

185 The first hypothesis is that modularity and hierarchy are an effective answer to the problems of model size and complexity. It takes advantage of the hierarchical structure of the process architecture around different levels of functionality (actuation and measurement, control and monitoring, plant operation and management...) and operational devices (field devices such as valves and pumps, PLCs, SCADA systems).

190 Several research works (Multilevel Flow Modelling [29]) or international standards (ANSI/ISA-88.01-1995 standard [30]) provide guidelines for modelling complex industrial processes according to recommended hierarchy schemes. Applications for critical industrial processes, such as chemical and energy processes, are available [31] and will be our basis for producing modular and hierarchical TA architecture models.

The second assumption is that the reuse of models is essential to make our approach acceptable and applicable in an engineering process. Indeed, as many architectures have to be evaluated during the engineering process, a major issue is then the ability of modelers to easily build and modify the system model (for example by adding or removing component models). Pattern-based modeling, combined with a structured modeling framework, seems to be a very efficient way to allow a plug-and-play approach to compose models from a library of generic and reusable models: [32, 33, 34]. These models must have standard interfaces to ensure their interoperability and can be adapted and composed according to the architecture to be modelled.

4.2. Chosen modelling formalism : Timed Automata

210 As mentioned previously, the chosen modeling formalism is based on timed automata defined by [26] as an extension of finite state automata. A timed automaton is a 9-uplet $\mathcal{A} = (S, V, X, L, I, T, S_m, s_0, v_0)$ where:

- S , V , X and I are respectively finite sets of locations, variables, clocks and invariants that label locations with some clock constraints,
- L is a set of synchronization labels (or channels) divided into emitting labels L_e (noted *label!*) and reception labels L_r (noted *label?*),
- T is a set of transitions $(s, l, g, m, s') \in S \times L \times G \times M \times S$ where G is a set of guards (crossing constraints on variables of V and clocks of X) and M a set of updates on the valuation of variables and clocks¹; l , g and m are optional,

¹Notation convention: synchronization labels are followed by ! or ?, guards are between brackets [], and updates are under the following form: $v = value$

- $S_m \subseteq S$, $s_0 \in S$ and $v_0 \in V$ are respectively the set of marked locations, the initial location and the initial values variables of V .

The state of a TA is described in a triplet $state_{\mathcal{A}} = (s, v, x)$, where s is the active location, v is the set of variable values and x is the set of clock values. It can evolve in two cases: after a transition crossing or after a lapse of time (evolution of the clocks) if the invariant is maintained.

An execution trace $\gamma = (s_1, x_1, v_1) \xrightarrow{t_1} (s_2, x_2, v_2) \dots \xrightarrow{t_n} (s_n, x_n, v_n)$ is a sequence of size n alternating states and transitions with $|\gamma| = n$.

A network of m timed automata, $\mathcal{NA} = \mathcal{A}^1 \parallel \mathcal{A}^2 \parallel \dots \parallel \mathcal{A}^m$ consists in a set of timed automata which can evolve in parallel (symbol $\parallel$). A network provides structuring mechanisms to represent the synchronisation of timed automata through channels (emission and reception labels) and shared variables or clocks. The overall state of the network is a triplet $state_{\mathcal{NA}} = (rs, rv, rx) \in STATE_{\mathcal{NA}}$ where rs is the set of active locations, rv is the set of variables values and rx is the set of clocks values. An automata network $\mathcal{NA}$ evolves with:

- a local evolution in an automaton of the network (if not related to a synchronisation label),
- the simultaneous crossing of both transitions t_p^α, t_q^β of an automata couple (A^α, A^β) with t_p^α and t_q^β respectively labelled by $l_p!$ and $l_q?$ such as $l_p^\alpha = l_q^\beta$, source locations of t_p^α and t_q^β are active and their guards satisfied.

An execution trace on a timed automata network $\Gamma = S_1 \xrightarrow{T_1} S_2 \dots \xrightarrow{T_N} S_N$ is an alternating sequence of states and transitions where S_i is a state of the automata network $\in STATE_{\mathcal{NA}}$, and T_i is either a transition of the automata network, or a couple of transitions (t_p^α, t_q^β) crossed simultaneously in the case of a synchronization channel.

4.3. Principles of the use of reachability analysis for architecture validation

This subsection presents the general framework of the proposed approach (Figure 1). The proposal is based on the definition of modelling patterns (Process and Sequencer Models) which are presented in the section 5, on the analysis of the reachability thanks to model-checking then on the analysis of the resulting trace in terms of action sequences to validate or invalidate the architecture.




Figure 1: Framework for architecture validation

4.3.1. Reachability analysis by model-checking

The reachability analysis is designed to return a trace of execution from the initial state of the sequencer to the state mentioned in the CTL property. As seen in the section 3, formal model-checking techniques [35] allow, thanks to automatic state space traversal mechanisms, to prove (or disprove) that a model satisfies (or does not satisfy) a formal property, which can be a reachability property.

If a path to the target state of the sequencer model exists, then the property will be satisfied and a model-checking tool will be able to provide an execution trace leading to this target state. A trace is then an alternating sequence of states and transitions $\Gamma = S_0 \xrightarrow{T_1} S_1 \dots \xrightarrow{T_n} S_n$ on the automata network where S_i represents a state and T_j a transition.

It is important to note that the generated trace is often the first path leading to the property check that is encountered when exploring the state space. It is therefore totally dependent on how the model-checker conducts its exploration (in width or depth, for example). The operational relevance of this sequence may be questioned, but the objective of the approach proposed here is only to show that it is possible to reach a target situation, and not to try to make a system work in an optimal way. However, some model-checkers offer the possibility of providing an optimal trace (in terms of length or duration of the sequences) but with a major drawback linked to the problem of combinatorial explosion since it requires exploring the entire state space.

4.3.2. Architecture validation

If such a trace can be provided, it means that there is a sequence of actions that meets the operational requirements of the facility for the analyzed context expressed through the sequencer. Otherwise, a failure of the proof means that the objective is not achievable and will probably require an evolution of the designed architecture.

From the traces that are generated, it is then possible to interpret the process operations which are sequences of steps specifying the actions and observations to be made on the process to go from a given state (considered as initial) to a desired state (considered as final). The trace given by the model-checker shall be processed to present the sequence of actions as understandable in the context of the operation of the plant. For the purpose of this study, only the actions to be applied to the process devices shall be considered. This leads to the application of a projection function on the generated run-time trace to filter the observations, i.e. the transitions identified by a report, in order to keep, for each transition drawn, only the source and reached states (locations, variables and clocks) and the requested actions.

4.4. Generation of action sequences

As presented in Figure 1, the reachability of a target location in the sequencer model requiring the process models is a safety indicator to validate the

architecture against the scenario described in the sequencer model under bound-
 295 ary conditions (especially in case of unavailability of some devices). Proof of
 reachability is given in the form of an execution trace from which a sequence of
 actions for plant operation can be deduced.

4.4.1. Reachability properties and generation of execution traces

The reachability property to be proved is modelled using a CTL (Com-
 300 putation Tree Logic) formula. The CTL language uses logical and temporal
 operators to formalize different types of properties: among them, the quanti-
 fiers **A** means 'along the whole path' (inevitably) and **E** means 'along at least
 one existing path' (possibly). These quantifiers can be complemented by path
 specific quantifiers such as **G** for 'Overall' and **F** for 'Finally'. Therefore, the
 305 reachability property of a sequencer will be represented as a combination of **E**
 and **F** as follows : **EF sequencer . $s_{expected_state}$** .

Verification of the reachability property $EF \text{ Sequencer.EndOfSequence}$ on
 models $S_N, M_N, M_{N-1}, \dots, M_1$ can be formalized as:

$$\Gamma \leftarrow (M_N \parallel M_{N-1} \parallel \dots \parallel M_1 \parallel S_N) \models EF S_i.EndOfSequence$$

310 where Γ is the trace of execution sought and $\models$ is the relationship of sat-
 isfaction. The obtained execution trace contains a sequence of states (active
 locations, clocks and variables) and transitions leading to the target location of
 the sequencer. An example of such a trace is given in Figure 2.




Figure 2: Example of execution trace

4.4.2. Generation of an admissible action sequence

315 While a sequence of execution may be sufficient to prove the existence of a
 safe operating path, its interpretation and understanding by a plant operations
 expert is not without significance. Indeed, it often contains many transitions
 that make sense only for the internal evolution mechanisms of the models.

From the plant operation point of view, a sequence of actions consists of
 320 the different operations that must be performed sequentially on the process
 elements. Depending on the context, these may be field devices (process mod-
 els M_1) such as actuation and measurement systems (opening/closing a valve,
 starting/stopping a pump, a motor, configuring a transmitter, ...) or computer
 devices (M_i with process models $i \geq 1$) to control or operate the plant (start-
 325 ing/stopping a function, an operating mode, a subsystem, ...). Each step of an
 action sequence identifies the action to be executed and defines the initial and
 reached situations.

Formally, an action is defined as a 4-uplet $(label, v_d, v_f, n)$, where $label$ contains a Req_i^p request to be applied on the p element at the i level to change its state, v_d and v_f contains the values of the observation variables ($Obs_M_i^p$) and the clocks respectively before and after the action, and n indicates the hierarchical level of the actuated element.

The algorithm 1 allows to generate an action sequence Δ associated with Γ . In order to respect the semantics of an action sequence, the basic principle used in the logic of the algorithm is close to a projection function, since it consists in extracting from the Γ trace all the transitions that do not involve actions to be performed on one of the elements of the process, and in constructing timestamps, values of the variables and states before and after actions.

Algorithm 1 Generation of action sequence Δ for $S_N \| M_N \| M_{N-1} \| \dots \| M_1$

Require:

$\Gamma = E_1 \xrightarrow{T_1} E_2 \dots \xrightarrow{T_N} E_X$ % Execution trace %

Ensure:

$\Delta = \delta_1 \delta_2 \dots \delta_X$ with $\delta_s = (label \in L, v_d \in V, v_f \in V, n \in \mathbb{N}^*)$

% $Ch(T_k)$ returns the channel (report or request) that labels the transition T_k if it exists or null otherwise.

% $V(E_i)$ returns the value of variables of the state E_i in the execution trace and the value of the global clock.

% $\Sigma_r^{M_{i-1}^p}$ is a subset of the alphabet associated to the automata M_{i-1}^p that only contains request channels.

$k \leftarrow 1$; $s \leftarrow 1$

for $k=1$ **à** X **do**

if $T_k = (t_\alpha, t_\beta) \wedge t_\alpha \in M_i \wedge t_\beta \in M_{i-1}^p \wedge Ch(T_k) \in \Sigma_r^{M_{i-1}^p}$ **then**
 $label \leftarrow Ch(T_k) = Req_{i-1}^p$; $v_d \leftarrow v(E_k)$; $v_f \leftarrow V(E_{k+1})$; $n \leftarrow i - 1$
 $\delta_s \leftarrow (label, v_d, v_f, n)$; $s \leftarrow s + 1$

end if

if $(T_k = t_\alpha) \wedge (t_\alpha \in S_N)$ **then**
 $label \leftarrow \varepsilon$; $v_d \leftarrow v(E_k)$; $v_f \leftarrow V(E_{k+1})$; $n \leftarrow N$
 $\delta_s \leftarrow (label, v_d, v_f, n)$; $s \leftarrow s + 1$

end if

$k \leftarrow k + 1$

end for

return $\Delta = \delta_1 \delta_2 \dots \delta_{s-1}$

5. Pattern-based hierarchical modelling

The previous section introduced the principles of using Reachability Analysis for architecture validation. This approach is based on a modelling framework for process and sequencer models that is presented in this section. This framework uses hierarchical and standardized synchronization mechanisms. An originality

is the definition of generic models to systematize the modelling of process and
 345 sequencers and to promote the reuse of models. The standardized variables
 and elementary generic structures of the TA patterns will be stored in a library
 from which the process and sequencer models will be built using a plug-and-play
 approach. The expected benefits are the reduction of modelling activity time
 since model building is done through specialization and model instantiation.

350 5.1. Models structure

5.1.1. Process models

Process architecture modelling promotes hierarchy and modularity. For
 these reasons, we consider that a process architecture is structured in N hi-
 erarchical levels (left part of Figure 3). These levels can be identified using
 355 ANSI/ISA-88 or internal company practices. The set of higher level models cor-
 responds to the plant operating recipe and will be denoted as M_N while the set
 of lower level models relates to field devices and will be denoted as M_1 . Each
 level i involves a set M_i of models denoted as M_i^k describing a component k
 belonging to that level. The details of these models will be given later in this
 360 section.




Figure 3: Structured process models M_i with a sequencer model S

The hierarchical communication between components is based on the classic
 semantics of requests and reports. The evolution of reports on a k component
 of level i may require the use of one or more resources belonging to level $i - 1$,
 which means that these resources must also be the scene of state changes. This
 365 is represented by a channel Req_{i-1}^p where a model $M_i^p \in M_i$ sends a query
 to a model $M_{i-1}^k \in M_{i-1}$. In Figure 3, all queries sent by the level $N - i$ are
 grouped under the notation Req_{N-i-1} . The orientation of the arcs represents a
 synchronization of the sent label (!) with the received label (?). By construction,
 lower-level templates M_1^p cannot request any resources.

370 In response to a state change request from a level $i + 1$, the requested model M_i^p will report a message when its state change has occurred. This message is modeled by a synchronization channel Rep_i^p . In Figure 3, all reports sent by the level $N - i$ are grouped under the notation Rep_{N-i-1} .

375 In addition to this query/report mechanism, the evolutions of all models can be conditioned by shared global variables representing physical variables or clocks.

5.1.2. Sequencer model

A sequencer is used to describe the plant operating scenario to be evaluated. In principle, it represents the initial process situation and one or more target
380 situations. The transitions between these situations are conditioned by various constraints concerning physical variables, the state of some field devices, the state of functions or the operational state of the plant. Operators and engineering know-how help characterize these constraints which are, by definition, specific to each scenario.

385 The sequencer interacts with the highest level of the process model M_N via the same request/report semantics using the Req_N and Rep_N synchronization channels (right part of Figure 3).

5.1.3. Modelling hypotheses

At this step, some very important assumptions need to be highlighted. The
390 first concerns the synchronisation of the models. The request sent by a component does not contain any explicit action that the called resources must execute. This only means that the state of these resources does not meet the requirements of the state the requester wants to reach and, therefore, a change in the state of the resources is mandatory. The appropriate evolution taken by the
395 resource to meet the conditions set by the requester will be randomly selected during the reachability analysis process until a solution is found. Similarly, if several resources are able to provide the services requested by a component, the model for that component will contain several transitions, each of which will be labelled by a request to a resource, without identifying a choice between the
400 resources requested. Again, this role will be assigned to reachability analysis.

The second hypothesis concerns the modelling of the evolution of physical quantities. In the models, it is represented by loop transitions on stable states. The crossing of these transitions is only conditioned by a clock invariant and triggers a modification of the value of the physical quantity concerned. For the
405 purposes of this article, since the systems concerned are mainly composed of valves, pipes and pumps with constant and controlled flow rates, the modelling of the evolution of the physical parameters depends on conditions that can be modeled by first-order relationships. This discretization is therefore represented by fixed increments or decrements, the value of which depends on the clock value
410 chosen to cross the transition. This may depend, for example, on the flow rate of a pump. The incrementation and decrementation of a physical quantity is included in only one model, which ensures that there will be no simultaneous changes or multiple updates.

415 The third hypothesis concerns the synchronization of the models. Figure 3 shows the exchanges between the process models at different levels, as well as with the sequencer model. These exchanges of requests and reports are updates, and not communications between distributed components of the considered system. For this reason, there is no latency when synchronizing the models.

5.2. Variable patterns

420 Standardised synchronisation mechanisms, based on query/report semantics (Req_i or Rep_i), do not contain all the necessary information on the status of the process and sequencer models. This information is nevertheless mandatory because the conditions of evolution within a model may depend on it (such as functional or availability constraints, exclusion guards...). This information is 425 modelled by shared variables that can be written or read in the process and sequencer models :

- the observation of the active locations of the model M_i^k is recorded in the variable noted $Obs_M_i^k$; these variables can be boolean, in the case of a model having only two locations of interest, or integer otherwise; these 430 variables are updated when the locations of interest are reached;
- physical values Φ ; these variables are integer and are updated by the models that act on them;
- the availability of a device described by the M_i^k model is recorded in the $Avail_M_i^k$ boolean variable. These variables are used to characterize the 435 operating scenario analyzed in the presence of certain unavailable devices and/or functions. They are set at model initialization, before the reachability analysis, to evaluate the reachability of a target situation given the known unavailability of some devices.

5.3. Location pattern

440 The modelling pattern for process and sequencer models is based on the concept of stable locations and on a set of transitions between two stable locations. A stable location in a model M_i^k is a location whose deactivation requires the receipt of a state change request. A stable location is a location such as :

- all output transitions must be at least labelled by a synchronization label 445 $Req_i^k ? \in L_r$,
- by symetry, all input transitions have to be labelled by synchronization label $Rep_i^k ! \in L_e$.

In addition, we consider that a change in physical values can only be made when a stable location is active. These modifications are modelled using a self-loop transition on the stable location that updates the shared integer variables 450 Φ . This discrete modelling of the physical variables was considered sufficiently efficient by plant operations experts in our studies. The time step that evaluates the periodic evolution of the physical variables is given by the *step* parameter that is used as a guard for self-loop transitions.

455 5.4. Transition patterns

Sets of transitional locations between stable locations ensure the preparation and closure of operations executed in stable locations. Generic semantics are given by the following sequence: a component receives a request from a higher level to change its internal stable location, then it calls one or more resources
460 from lower levels and finally sends a status to the higher level when the new stable location is reached. Therefore, transitions from one stable location of M_i^k to another can be labelled by three types of channels :

- a request $Req_i^k?$ received from higher level that justifies leaving the current stable location;
- 465 • several requests $Req_{i-1}^p!$ that request resources for state changes; all channels that request resources are grouped together in a set noted $\{Req_{i-1}^p\}$;
- a report $Req_i^k!$ sent to a higher level when a new stable location is reached.

The authorization of a transition sequence between two stable sites may depend on conditions related to the availability of the requested resources, the configuration of the requested resources and security constraints. These conditions
470 are formalized by generic guards.

The availability constraint is formalized by a boolean guard $G_{avail}^{(s_a, s_b)}$, defined for a pair of stable locations (s_a, s_b) by:

$$G_{avail}^{(s_a, s_b)} = [f_{avail}^{(s_a, s_b)}(Avail_M_{i-1}^p) == TRUE].$$

475 This constraint is computed by function $f_{avail}^{(s_a, s_b)}$, which is specific to each process model, from shared variables $Avail_M_{i-1}^p$ indicating the availability of the resources called. If and only if the resources needed for the configuration are all available, then the function returns the value *true*.

The configuration constraint represents the active locations of the called
480 resources and/or the values of certain physical variables that must be satisfied to allow the new stable location of the requester. Configuration conformance for a stable location s_a is formalized by a boolean guard $G_{conf}^{s_a}$ defined by :

$$G_{conf}^{s_a} = [f_{conf}^{s_a}(Obs_M_{i-1}^p, \Phi) == TRUE].$$

This constraint is computed by the function $f_{conf}^{s_a}$, which is specific to each
485 process model, from the shared variables $Obs_M_{i-1}^p$, and Φ .

Finally, security constraints represent some properties that must be satisfied before a requester is allowed to call a given resource. These properties can be linked to priority rules (for example, a pump's engagement can only be required if upstream valves are open) or exclusion constraints (for example,
490 incompatibility between the execution of two given functions). In other words, when a resource $M_{i-1}^p!$ is requested by a channel $Req_{i-1}^p!$, the safety constraint requires that the active locations of some same-level elements and/or the values of certain physical variables be respected. It is formalized as a boolean guard G_{safe}^p defined as :

495

$$G_{safe}^p = [f_{safe}^p(Obs_M_{i-1}^l, \Phi) == TRUE].$$

where $l \neq p$ (safety constraint on the requested element p relates to the other elements l). This constraint is computed by function f_{safe}^p , which is specific to each process model, from the shared variables $Obs_M_{i-1}^p$, and Φ . If and only if the safety constraints are satisfied, then the function returns the value *true*.

500 5.5. “Two stable locations” pattern for process models

The generic structure between two stable locations of a model M_i^k for $i \neq 1$ is given in Figure 4a.

The transition from the stable location s_a to the stable location s_f is crossed upon receipt of a request $Req_i^k?$ from a model M_{i+1}^q (this request is issued
505 between the locations s_b and s_c of M_{i+1}^q). This request can only be accepted if the availability guard G_d is true.

Assuming the request is enabled, the model starts calling lower-level resources until the conditions for reaching the stable location s_f are met. The loop between s_b and s_c represents the successive requests Req_{i-1}^p sent to the
510 resources (these requests are received by M_{i-1}^q between s_a and s_b) until the requirements $G_f^{s_f}$ for the stable location s_f are met. The $s_b \rightarrow s_c \rightarrow s_b$ trace means that a resource was requested and responded positively but did not satisfy the configuration guard $G_f^{s_f}$. This sequence is executed until $G_f^{s_f}$ is true and reaches the s_d location.


The transition from s_d to s_e is intended to update the observation variable $Obs_M_i^k$ after time $t_{M_i^k}$ has elapsed. This time, which can be null, represents the transfer time from one stable location to another. Finally, the transition
515 from s_e to s_f is only used to send a status change report $Rep_i^k!$ to M_{i+1}^q (this report is received between locations s_c and s_b or s_c and s_d).

The same process is applied for modelling the transient sequence between
520 the stable location s_f and the stable location s_a .


In order to reduce the number of request transitions in a model M_i^k (potentially equal to the number of level $i - 1$ elements), it is possible to restrict them only to the level $i - 1$ resources used by the M_i^k element. This is formalized by
525 [35] through a set called cone of influence. In our case, this set is a set of requests $Req_{i-1}^p!$ which is computed by listing the observations $Obs_M_{i-1}^p$ and the physical values $\Phi(M_{i-1}^p)$ involved in the configuration guards of M_i^k . This cone of influence is defined as $\mathcal{C}(M_i^k) = \{Req_{i-1}^p\}$ for all p where either $Obs_M_{i-1}^p$ or $\Phi(M_{i-1}^p)$ belongs to the guard $G_c^{s_x}$ for all stable locations s_x of the model M_i^k .

Finally, let us recall that the set $\{Req_{i-1}^p \in \mathcal{C}(M_i^k)\}$ which labels some
530 transitions (for example from s_b to s_c) is a notation convention which actually represents a set of transitions, each of them being labelled by an element of the set $\{Req_{i-1}^p\}$.

For lower level process models M_1 (valves, pumps, sensors, ...), the pattern is
535 given by Figure 4b. The transient sequence from one stable location to another has no resources to trigger. Consequently, no functional constraints are taken



(a) Pattern for M_i^k models



(b) Pattern for M_1^k models

Figure 4: Two stable locations pattern

into account, and safety constraints are ensured by the higher levels. The two
stable location model of Figure 4a is then simplified by substituting the locations
540 and transitions from s_b to s_d by a single location (similarly for s_g to s_i). The
only guard considered is the availability constraint but its semantics needs to
be adapted. Indeed, talking about availability of lower level resources makes
no sense but availability must be considered for the device itself since it must
be available to be triggered. The guard $[G_d^{(s_a,s_f)}]$ is then substituted by a
545 guard $G_d = Avail_M_i^k$, where $Avail_M_i^k$ is a boolean variable representing the
availability of the element M_i^k .

5.6. Using patterns to structure process models M_n

The generic pattern proposed in the previous section allows to systematically
obtain the evolution model between two stable locations of a process element.

550 If this process element has only two stable states, which is often the case
(on/off valve, pump, two-mode functions such as off and on, ...), the model of
the process element is similar to the generic model. It will suffice to define the
functions $f_{avail}^{(s_a,s_f)}$, $f_{conf}^{s_a}$, $f_{conf}^{s_f}$ and f_{safe}^p which are specific to each model.




Figure 5: Macro-locations

Otherwise, in the case of a number of stable locations greater than two
 555 (three-way valves, functions with several modes such as off, on, gradient, ...),
 the process model is obtained by applying the "two stable locations" for all pairs
 of stable locations.

To simplify the representation of the models, a graphical notation of macro
 560 localization, inspired by the Grafcet macro step of the IEC 60848 standard
 [36, 37], is proposed. A macro-location P_{io} , whose notation is given in the left
 part of the Figure 5 is characterized by an input location s_i , an output location
 s_o and inner locations s_{int} . The transition from a s_x location to a macro-location
 565 is a graphical representation of the transition from that s_x location to the s_i
 input location of the macro location; the transition from a macro-location to
 a s_y location is a graphical representation of the transition from the s_o output
 location to that s_y location.

The right part of Figure 5a shows the expansion of a macro-location repre-
 senting the sequence from s_b to s_e of the template pattern given in Figure 5a
 570 while the right part of Figure 5b shows the expansion for M_i^k templates. As this
 notion is only a graphical notation, the syntax and semantics of macro-locations
 remain classical.

A process model using macro-locations must satisfy the following two prop-
 erties :

- 575 • there is at most one P_{ab} macro location from the stable s_a to the stable
 s_b location regardless of a and b ,
- a stable s_a location must have at least one output transition to a P_{ab}
 macro transition with $a \neq b$.

The building of a model with k stable locations depends on the transitions
 580 between the different stable locations. If a change between two stable locations,

for example from s_a to s_b , is to be modeled, then a P_{ab} macro-location is placed between these two stable locations, and two transitions are defined from s_a to the input location of P_{ab} and from the output location of P_{ab} to s_b . Figure 6 gives an example where 3 stable locations can be reached using 5 paths.




Figure 6: Example of model using macro-locations

5.7. Patterns for sequencer models S

As presented in Figure 3, the sequencer model is synchronized with the models M_N using two channels: transmission of a set of requests $\{Req_N^k! \in Req_N\}$ and receiving a set of reports $\{Rep_N^k? \in Rep_N\}$.

The sequencer has an initial location, noted s_a , and an expected location, noted s_c . The change from s_a to s_c corresponds to the operating scenario being evaluated. Recalling that the objective is to find an execution trace on the process models M_i , the sequencer will use the request channels to trigger the process models as resources helping to reach its expected location. Accordingly, the sequencer iteratively sends requests to the M_N^k models if the security conditions ($f_{safe}^k(Obs_M_N^k, \Phi)$) are met, until the conditions in terms of active locations of the M_N^k models and physical values $f_{conf}^{s_c}(Obs_M_N^k, \Phi)$ are met. Iteration is supported by the first transition from s_a to s_b and by self-loop transitions on the location s_b . An example of a sequencer automaton is given by the Figure 7, where the location s_c represents the desired target situation.




Figure 7: Sequencer pattern

600 This generic pattern can be used in combination, as with process patterns, to create compound sequencers. It can be useful to describe a sequence of phases in which the physical values must reach different sets of values: for example, a preparation phase, then an equilibrium state, and finally a closing phase.

6. Application using an Industrial case study

6.1. Presentation of the case study

605 The CISPI platform is part of a larger demonstrator developed within the CONNEXION project². It is dedicated to research work on industrial process management, which involves a set of complex processes covering different functional modes (production, shutdown, start-up, ...) and critical modes (normal, incident and accidental operation).

610 The CISPI platform provides auxiliary water supply to other systems and is structured in three hierarchical levels with a large number of hardware and functional redundancies: 22 field equipments (M_1) can be configured to perform 24 process functions (M_2) to reach different operational situations of a recipe (M_3). A partial flowchart of the platform is given in Figure 8.

620 The objective is to validate the process architecture by demonstrating that a target situation can always be reached safely even if some resources are not available or if changes have been made to the process and its control. The initial situation is as follows: the valves are closed, the pumps do not work, tank 001BA is full of water and tank 002BA is empty. The target situation is to supply tank 002BA with water up to a volume of 10 volume units. Three scenarios are proposed, which differ in terms of equipment availability :

- Scenario 1: all devices are available;
- Scenario 2: all devices are available except valves $VM3$ and $VE3$ and pump $PO1$;
- Scenario 3: all devices are available except valves $VE1$ and $VE3$.

²CONNEXION (French Excellence in Nuclear Control Systems) is a research project on the safety of control systems in the nuclear industry. It was supported by the French government.




Figure 8: Process flow diagram of the CISPI platform

6.2. Case study modelling

The implementation of the models of recipes, functions, devices and sequencers with timed automata, as well as the reachability analyses, were performed with the UppAal model checking tool [38]. The models presented in the section 5 have been implemented into the UppAal tool, which conforms to TA semantics, to model equipment, functions and process recipe. Although the language proposed by Uppaal is more expressive than the traditional TA definition and may allow the creation of more "readable" models, we chose to use TA to facilitate model and approach portability.

As discussed in the previous section, the main advantage of using TAs is that it reduces the time required to build the model. The UppAal tool has

component-oriented features that allow the creation of parametric "templates", which can be used as generic models and then instantiated. Therefore, defining process models for an architecture is similar to a plug-and-play process that selects process models from the library. Their parameterization is done according to parameter tables (for variables, constants and clock thresholds) and functions (for the definition of guards) which are interpreted by C_# scripts to set up the UppAal automata.

Figure 9a provides the UppAal implementation of the process model (at the level ≥ 2) and Figure 9b gives an example of the instantiated valve model VM21. Note that a double circled UppAal location is an initial location.




Figure 9: Implementation of process models with UPPAAL

6.3. Results and analysis

For Scenario 1, a proof of success has been returned, meaning that a safe sequence of action exists to reach the target state of the sequencer. An execution trace has been proposed and has been interpreted according to Algorithm 1 as:

1. Configure function CpCsExt1G

- (a) Open valve VR3
- (b) Open valve VM3
- (c) Start pump P03
- (d) Open valve VE3

2. Wait 10 time units
3. Objective situation is reached

For Scenario 2, for which *VM3*, *VE3* and *PO1* are not available, it was also possible to achieve the target situation by opening the valves *VM1*, *VR3*, *VM23*, *VM26* and *VE1*, starting the pump *PO1* and waiting 10 units of time. This means that the considered architecture is valid with respect to the operational objective, in the considered architecture configurations.

On the opposite, a proof of failure has been returned for scenario 3 where neither *VE1* nor *VE3* are available. This means that if the operational situation being assessed occurs, the current CISPI architecture will not be able to respond in a safe manner.

Even if an architecture is valid, this does not mean that the generated sequences are operationally valid. Indeed, a generated sequence can use the same device several times, on opposite actions which are consequently useless actions, or be very long compared to others. One way to validate generated sequences is to obtain the operator's point of view. If several sequences are generated for the same case, some may be considered better than others, and the operator will then have to make a choice between them. This choice can be made according to different criteria such as, for example, the duration of the sequence, the number of actions in the sequence, or the geographical distance between devices.

The simulation of the generated traces or sequences can be useful for such activities. A prototype has been developed in this way in the CONNECTION project. The process behavior has been simulated with Alices³ while the control and operation of the plant has been implemented with Scade⁴. The generated sequences were run by an operator on this coupled simulation to visualize and evaluate the relevance of the generated sequence.

7. Conclusion and open issues

The objective of the work presented in this paper is to propose an approach to validate as early as possible the operability of the architecture of safety-critical systems. It considers operational validation from the operator's point of view. The approach is based on reachability analyses of timed automata representing the process behaviour, which are initiated by the operators. If the situations characterized by the operators are reachable, the architectures considered are valid; otherwise, the architectures are not and must be modified.

The proposal of a formal modeling framework, based on patterns, favors their reuse for many architecture validations. In this way, the modelling effort, and thus the time and cost of modelling, is reduced.

³Alices is a tool for the full-scale simulation of a power plant developed by CORYS.

⁴Scade is a formal simulation and verification tool for embedded control systems developed by ANSYS.

695 Work in progress is the definition of a library of models and patterns that
 could be used to facilitate the composition of process models and sequencers.
 The open issues in this definition are the classification criteria and the level of
 detail that the model author must address. Indeed, depending on the expertise
 of the user, different levels of detail may be required: for example, a low level
 700 may be required in the case of an operator who wants to validate an architecture
 in a particular situation, or a high level in the case of a modeler who proposes
 a new model.

Beyond the reachability analysis, which enables an architecture to be vali-
 dated, the use of model-checking on models developed according to the proposed
 705 approach enables the models to be validated, in particular from the point of view
 of operating safety. In other words, from a physical point of view, it is a ques-
 tion, for example, of checking that physical quantities do not exceed certain
 thresholds (is the volume of the tank greater than a safety level?). From an
 operational point of view, it may be necessary to check that a configuration has
 710 been carried out before starting an action (is the valve open before starting the
 pump?).

Another major problem in using reachability analysis is the risk of combina-
 torial explosion that often occurs when verifying large-scale models, as shown
 by previous preliminary work on the feasibility of generating action sequences
 715 [39]. The fact that the systems covered are very large justifies the use of dif-
 ferent levels of abstraction to progressively construct action sequences through
 iterative refinement.

8. References

- [1] L. Mårtensson, Are operators and pilots in control of complex systems?,
 720 Control Engineering Practice 7 (2) (1999) 173 – 182.
- [2] J. Lahtinen, J. Valkonen, K. Björkman, J. Frits, I. Niemelä, K. Heljanko,
 Model checking of safety-critical software in the nuclear engineering do-
 main, Reliability Engineering & System Safety 105 (2012) 104–113.
- [3] C. Devic, P. Morilhat, Connexion contrôle commande nucléaire numérique
 725 pour l’export et la rénovation - coupler génie logiciel et ingénierie système
 : source d’innovations, Génie Logiciel 104 (2013) 2–11.
- [4] O. Goubali, P. Girard, L. Guittet, A. Bignon, D. Kesraoui, P. Berruet,
 J.-F. Bouillon, Designing functional specifications for complex systems, in:
 International Conference on Human-Computer Interaction, Springer, 2016,
 730 pp. 166–177.
- [5] D. Galara, Roadmap to master the complexity of process operation to help
 operators improve safety, productivity and reduce environmental impact,
 Annual Reviews in Control 30 (2) (2006) 215–222.

- 735 [6] N. Foulkes, M. Walton, P. Andow, M. Galluzzo, Computer-aided synthesis of complex pump and valve operations, *Computers & Chemical Engineering* 12 (9) (1988) 1035–1044.
- [7] J. Rushby, Using model checking to help discover mode confusions and other automation surprises, *Reliability Engineering & System Safety* 75 (2) (2002) 167–177.
- 740 [8] M. Bouissou, J. Bon, A new formalism that combines advantages of fault-trees and markov models: Boolean logic driven markov processes, *Reliability Engineering and System Safety* 82 (2) (2003) 149–163.
- [9] C. G. Cassandras, S. Lafortune, *Introduction to discrete event systems*, Springer, 2008.
- 745 [10] C. A. Petri, *Communication with automata* (1966).
- [11] T. A. Henzinger, The theory of hybrid automata, in: *Verification of Digital and Hybrid Systems*, Springer, 2000, pp. 265–292.
- [12] G. Rotstein, R. Lavie, D. Lewin, A qualitative process-oriented approach for chemical plant operations — the generation of feasible operation procedures, *Computers & Chemical Engineering* 16 (1992) S337 – S344, European Symposium on Computer Aided Process Engineering.
- 750 [13] A. Castelnovo, L. Ferrarini, L. Piroddi, An incremental Petri net-based approach to the modeling of production sequences in manufacturing systems, *IEEE Transactions on Automation Science and Engineering* 4 (3) (2007) 424–434.
- 755 [14] M. Theißen, R. Hai, W. Marquardt, A framework for work process modeling in the chemical industries, *Computers & Chemical Engineering* 35 (4) (2011) 679 – 691.
- [15] S. Viswanathan, C. Johnsson, R. Srinivasan, V. Venkatasubramanian, K. E. Årzen, Automating operating procedure synthesis for batch processes: Part i. knowledge representation and planning framework, *Computers & Chemical Engineering* 22 (11) (1998) 1673–1685.
- 760 [16] G. Godena, ProcGraph: a procedure-oriented graphical notation for process-control software specification, *Control Engineering Practice* 12 (1) (2004) 99 – 111.
- 765 [17] H. A. Gabbar, A. Aoyama, Y. Naka, Recipe formal definition language for operating procedures synthesis, *Computers & Chemical Engineering* 28 (9) (2004) 1809–1822.
- [18] E. M. Clarke, O. Grumberg, D. Peled, *Model checking*, MIT press, 1999.

- 770 [19] E. Németh, T. Bartha, C. Fazekas, K. M. Hangos, Verification of a primary-to-secondary leaking safety procedure in a nuclear power plant using coloured Petri nets, *Reliability Engineering & System Safety* 94 (5) (2009) 942–953.
- [20] D. Soliman, G. Frey, Verification and validation of safety applications based on plcopen safety function blocks, *Control Engineering Practice* 19 (9) 775 (2011) 929 – 946.
- [21] P. J. Ramadge, W. M. Wonham, Supervisory control of a class of discrete event processes, *SIAM Journal on Control and Optimization* 25 (1) (1987) 206–230.
- 780 [22] J. Zaytoon, B. Riera, Synthesis and implementation of logic controllers—a review, *Annual Reviews in Control* 43 (2017) 152–168.
- [23] Y.-F. Wang, H.-H. Chou, C.-T. Chang, Generation of batch operating procedures for multiple material-transfer tasks with Petri nets, *Computers & Chemical Engineering* 29 (8) (2005) 1822–1836.
- 785 [24] M.-L. Yeh, C.-T. Chang, An automata-based approach to synthesize untimed operating procedures in batch chemical processes, *Korean Journal of Chemical Engineering* 29 (5) (2012) 583–594.
- [25] S. Dai, M. Hong, B. Guo, Synthesizing power management strategies for wireless sensor networks with uppaal-stratego, *International Journal of Distributed Sensor Networks* 13 (4). 790
- [26] R. Alur, D. L. Dill, A theory of timed automata, *Theoretical Computer Science* 126 (2) (1994) 183–235.
- [27] C.-J. Wang, Y.-C. Chen, S.-T. Feng, C.-T. Chang, Automata-based operating procedure for abnormal situation management in batch processes, 795 *Computers & Chemical Engineering* 97 (2017) 220–241.
- [28] J.-H. Li, C.-T. Chang, D. Jiang, Systematic generation of cyclic operating procedures based on timed automata, *Chemical Engineering Research and Design* 92 (1) (2014) 139–155.
- 800 [29] M. Lind, An introduction to multilevel flow modeling, *Nuclear safety and simulation* 2 (1) (2011) 22–32.
- [30] ISA, ANSI/ISA-88.01-1995 : Batch control - part 1 : Models and terminology, The Instrumentation, Systems and Automation Society.
- 805 [31] M. Lind, H. Yoshikawa, S. B. Jørgensen, M. Yang, K. Tamayama, K. Okusa, Multilevel flow modeling of monju nuclear power plant, *Nuclear safety and simulation* 2 (3) (2011) 274–284.

- [32] H. Meng, L. Kloul, A. Rauzy, Modeling patterns for reliability assessment of safety instrumented systems, *Reliability Engineering & System Safety* 180 (2018) 111–123.
- 810 [33] M. Bonfè, C. Fantuzzi, C. Secchi, Design patterns for model-based automation software design and implementation, *Control Engineering Practice* 21 (11) (2013) 1608 – 1619.
- [34] S. Mouelhi, M.-E. Laarouchi, D. Cancila, H. Chaouchi, Predictive formal analysis of resilience in cyber-physical systems, *IEEE Access* 7 (2019) 33741–33758.
- 815 [35] E. Clarke, A. Biere, R. Raimi, Y. Zhu, Bounded model checking using satisfiability solving, *Formal Methods in System Design* 19 (1) (2001) 7–34.
- [36] IEC, IEC 60848: Grafcet specification language for sequential function charts.
- 820 [37] R. Julius, M. Schürenberg, F. Schumacher, A. Fay, Transformation of Grafcet to PLC code including hierarchical structures, *Control Engineering Practice* 64 (2017) 173 – 194.
- 825 [38] K. G. Larsen, F. Lorber, B. Nielsen, 20 years of uppaal enabled industrial model-based validation and beyond, in: T. Margaria, B. Steffen (Eds.), *Leveraging Applications of Formal Methods, Verification and Validation. Industrial Practice*, Springer International Publishing, Cham, 2018, pp. 212–229.
- 830 [39] T. Cochard, D. Gouyon, J.-F. Pétin, Generation of safe plant operation sequences using reachability analysis, in: *20th IEEE International Conference on Emerging Technologies and Factory Automation*, 2015.